



Manufactured by
Melpress Ltd Cert No
BC1377/0414



PRODUCT DATA SHEET

Triple X Concentrate System Chemicals

Silencer: TRIPCON4

Directions: *For use in indirect systems only.*

It is recommended that Tower Triple X Silencer is added to the system together with Tower Triple X Inhibitor to give maximum protection. Both products can be left in the system indefinitely. Tower Triple X Silencer is designed to reduce boiler noise in central heating systems caused by lime scale deposited onto the boiler heat exchanger. It is suitable for all types of systems including those containing aluminium.

Inhibitor: TRIPCON1 (BUILD CERT APPROVED)

Directions: For use in indirect systems only.

Triple X inhibitor prevents scale, corrosion, hydrogen gassing, boiler noise and micro biological growth. For best results systems should be flushed with Triple X Cleanser prior to adding Triple X Inhibitor.

Leak Sealer: TRIPCON5

Instructions: Shake bottle before opening and use entire contents. Suitable for use with Power Flushing machines, dose via the reservoir. For open vented systems, dose via the Feed/Expansion tank. Switch on system and bleed radiator as necessary. After completion of treatment, peel installation label from side panel and attach to boiler casing. Record date for future reference.

Technical Information: Leak sealer can eliminate damp patches under screed avoiding costly repairs. Add Leak Sealer to the central heating circuit. Leak Sealer is effective within 1 – 24 hours when a soft seal will form. One 0.5 litre bottle is usually sufficient to seal a typical domestic central heating system comprising 10 radiators. Compatible with all Eco central heating products. Corrosion protection must also be carried out by adding inhibitor.

Cleanser: TRIPCON2

Dosing: New Installations: Tower Triple X Cleanser should be circulated around the system, at normal running temperature with all valves open for two hours. Thoroughly flush the system before refilling and adding Tower Triple X Inhibitor.

Existing installations: Tower Triple X Cleanser should be circulated around the system, at normal running temperature, with all valves open, for a minimum of two hours or up to two weeks depending on the condition of the system, until satisfactory performance is obtained. Thoroughly flush system before refilling and adding Tower Triple X Inhibitor. This product was manufactured under a quality system accredited to ISO 9001 and an environmental management system accredited to ISO14001.

Each 0.5 litre container of Triple X Concentrate product is usually sufficient for a standard domestic heating system up to 100 litres (approx 10 radiators). It is acceptable to add Triple X Silencer, Inhibitor and Leak Sealer to the system and leave indefinitely.

SAFETY


KEEP OUT OF REACH OF CHILDREN AND ANIMALS. NOT TO BE TAKEN INTERNALLY. AVOID CONTACT WITH EYES, SKIN AND CLOTHING. IN CASE OF CONTACT, RINSE AFFECTED AREAS WITH QUANTITIES OF CLEAN, COLD WATER. NOT SUITABLE FOR USE WITH 'PRIMATIC' SYSTEM. DO NOT MIX WITH OTHER MANUFACTURERS CHEMICAL PRODUCTS.

- For open vented systems fill via header tank.
- For sealed systems fill via a radiator.



TFC GROUP LLP

TRIPLE X CONCENTRATE



Cert No: RS 30178
QR057

TFC GROUP LLP, TOWER HOUSE, VALE RISE, TONBRIDGE, KENT TN9 1TB

Tel: 01732 351680 Fax: 01732 354445 www.tfc-group.co.uk

Prepared for TFC Group LLP By: M. Edmonston

Issue 1: July 2018

Page 1 of 1