

**OPTIMUM
OP-2PORTH & OP-MIDH
Replacement actuator
fitting instructions**

1. Remove actuator cover.
2. Lock lever in “MAN” position.
3. Turn valve stem until flat is parallel as indicated.
4. Push actuator onto valve.
5. Tighten 2 securing screws.
6. Release lever and allow to travel back to “AUTO”.

