



TRADE RANGE

Concentrate System Chemicals

Product Code:
TT01 & TT02

Directions: For use in indirect systems only.

Inhibitor: Tower Trade TT01

Tower Trade inhibitor prevents scale, corrosion, hydrogen gassing, boiler noise and micro biological growth. For best results systems should be flushed with Cleanser prior to adding Tower Trade Inhibitor. It is acceptable to add Tower Trade Inhibitor into the system and leave indefinitely.

Cleanser: Tower Trade TT02

New Installations: Tower Trade Cleanser should be circulated around the system, at normal running temperature with all valves open for two hours. Thoroughly flush the system before refilling and adding Tower Trade Inhibitor.


Existing installations: Tower Trade Cleanser should be circulated around the system, at normal running temperature, with all valves open, for a minimum of two hours or up to two weeks depending on the condition of the system, until satisfactory performance is obtained. Thoroughly flush system before refilling and adding Tower Trade Inhibitor. This product was manufactured under a quality system accredited to ISO 9001 and an environmental management system accredited to ISO14001.

Each 0.5 litre container of Tower Trade Concentrate product is usually sufficient for a standard domestic heating system up to 100 litres (approx 10 radiators).

SAFETY: KEEP OUT OF REACH OF CHILDREN AND ANIMALS. NOT TO BE TAKEN INTERNALLY. AVOID CONTACT WITH EYES, SKIN AND CLOTHING. IN CASE OF CONTACT, RINSE AFFECTED AREAS WITH QUANTITIES OF CLEAN, COLD WATER. NOT SUITABLE FOR USE WITH 'PRIMATIC' SYSTEM. DO NOT MIX WITH OTHER MANUFACTURERS CHEMICAL PRODUCTS.

For use in indirect systems only.

- For open vented systems fill via header tank.
- For sealed systems fill via a radiator.



TRADE RANGE

TFC GROUP

TT01 & TT02 System Chemicals



Cert No: RS 30178

TFC GROUP, TOWER HOUSE, VALE RISE, TONBRIDGE, KENT TN9 1TB

Tel: 01732 351680 Fax: 01732 354445 www.tfc-group.co.uk

QR057 Prepared for TFC Group By: M. Edmonston

Issue 1: September 2019

Page 1 of 1